

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

REPORT OF BUILDING MATERIALS for						F	r	i	a	b	l	e	C	o	n	d	i	t	i	o	n	A	c	c	e	s	D	e	b	r	i	s	A	i	r	r	l	o	w	A	H	E	R	A	#	P	F	D	P	r	i	o	r	i	t	y	Sorted by: Area/Mat/Zone	
Disposition All		Selected:																																																								
HEADSTART CENTER FOR CHILDREN																																																										
Materials printed in BOLD must be treated as Asbestos Containing Materials																																																										
Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition																															Response	Quantity																					
001	Z1	C	CONCRETE, Floors/Walls/Ceilings └ NOTE: Beneath carpeting.	C	Exempt																																0 sf																					
	Z1	CT11M*	CEILING TILE, 12"x12" Mineral Board Panels *	CT6	Non-ACM																																0 sf																					
	Z1	CTM	CEILING TILE MASTIC	CT6M	Non-ACM																																0 sf																					
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM																																0 sf																					
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect																																0 sf																					
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect																																0 sf																					
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM																																0 sf																					
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect																																0 lf																					
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect																																0 sf																					
002	Z1	CT11M*	CEILING TILE, 12"x12" Mineral Board Panels *	CT6	Non-ACM																																0 sf																					
	Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT2	Non-ACM																																0 sf																					
	Z1	CTM	CEILING TILE MASTIC	CT6M	Non-ACM																																0 sf																					
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM																																0 sf																					
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect																																0 sf																					
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect																																0 sf																					
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM																																0 sf																					
	Z1	PD	PLASTER, Decorative Finish	P5	Non-ACM																																0 sf																					
	Z1	PICF	PIPE INSULATION, Cellular Foam	PICF	Non-Suspect																																0 lf																					
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect																																0 lf																					
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect																																0 lf																					
	Z1	PP	PLASTER PATCH, Smooth/Sandfloat Finish	P3	Non-ACM																																0 sf																					
	Z1	PS	PLASTER, Stucco Finish	P6	Non-ACM**																																0 sf																					
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect																																0 sf																					
003	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt																																0 sf																					
	Z1	CT11M*	CEILING TILE, 12"x12" Mineral Board Panels * └ NOTE: Above new ceiling.	CT6	Non-ACM																																0 sf																					
	Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT2	Non-ACM																																0 sf																					
	Z1	CTM	CEILING TILE MASTIC └ NOTE: Above new ceiling.	CT6M	Non-ACM																																0 sf																					
	ZR	CTR	CEILING TILE, Replacement Panels └ NOTE: Patch tile.	CTR	Non-Suspect																																0 sf																					
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM																																0 sf																					
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect																																0 sf																					
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12	O&M	160 sf																																													
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14	O&M	160 sf																																													
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect																																0 sf																					
	ZR	FTRSR	FLOOR TILE REDUCING STRIPS, Replacement Vinyl	FTRRS	Non-Suspect																																0 sf																					
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM																																0 sf																					
	Z1	PIAC	PIPE INSULATION, Air Cell & Associated Fittings └ NOTE: 5 lf above ceiling. Partially above ceiling.	PIAC	ACM	N	ND	N	N	N	LPD 14	O&M	55 lf																																													
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect																																0 lf																					

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

						F	C	A	D	A	A	P	P	Sorted by: Area/Mat/Zone Disposition All Selected:	
						r	o	c	e	a	H	F	r		
						i	n	e	s	r	E	D	i		
						a				l	R				
						b					#				
						l									
						e									
						n									
Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition									Response	Quantity
	Z1	PIWF	PIPE INSULATION, Woolfelt & Associated Fittings NOTE: Above ceiling.	PIW	ACM	N	ND	N	N	N		LPD 14		O&M	4 lf
	Z1	PP	PLASTER PATCH, Smooth/Sandfloat Finish	P3	Non-ACM										0 sf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic NOTE: Gray.	WBR4	Non-Suspect										0 sf
004B	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt										0 sf
	ZR	FDR	FIRE DOORS, Replacement	FDR	Non-Suspect										0ea
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt										0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	Z1	PP	PLASTER PATCH, Smooth/Sandfloat Finish	P3	Non-ACM										0 sf
005	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt										0 sf
	ZR	DIR	DUCT INSULATION, Replacement NOTE: Fiberglass w / foil jacket.	DIR	Non-Suspect										0 sf
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
006B	ZR	CTGR	CERAMIC WALL TILE, Replacement Tile, Grout & Associated Mastic	CTGR	Non-Suspect										0 sf
	ZR	CTR	CEILING TILE, Replacement Panels	CTR	Non-Suspect										0 sf
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt										0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P2	Non-ACM										0 sf
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
	Z1	ST	CUT/POLISHED STONE	MBL	Exempt										0 sf
007	Z1	BM	BRICK & MORTAR	B	Exempt										0 sf
	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt										0 sf
	Z1	CT11M*	CEILING TILE, 12"x12" Mineral Board Panels * NOTE: Above ceiling.	CT6	Non-ACM										0 sf
	Z1	CT24G	CEILING TILE, 2'x4' Gypsum Board Panels	CT5	Non-ACM										0 sf
	Z1	CTM	CEILING TILE MASTIC	CT6M	Non-ACM										0 sf
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting NOTE: Above ceiling.	DI	Non-Suspect										0 sf
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf
	Z1	FT9BN	FLOOR TILE, 9"x9" Brown Vinyl * NOTE: Remnant floor tile & mastic under counter.	FT3	ACM	N	ND	N	N	N		LPD 14		O&M	2 sf
	Z1	FTM	FLOOR TILE MASTIC NOTE: Remnant floor tile & mastic under counter.	FTM	ACM	N	ND	N	N	N		LPD 14		O&M	2 sf
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect										0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

						F	C	A	D	A	A	P	P	Sorted by: Area/Matl/Zone Disposition All Selected:	
						r	o	c	e	i	H	F	r		
						a	n	c	r	r	E	D	i		
						b	i	e	s	f	R	P	p		
						l	t	s	l	l	#	d	r		
						e	o					y			
Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition									Response	Quantity
008	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect										0 lf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect										0 sf
	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt										0 sf
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting	DI	Non-Suspect										0 sf
	Z1	DWJC	WALLBOARD, Drywall/Joint Compound System	DW	Non-ACM										0 sf
	Z1	FDWM	FIRE DOORS, Wood Shell w / Mineral Core	FD2	Non-ACM										1 ea
	Z1	FTRSBN	FLOOR TILE REDUCING STRIPS, Brown Vinyl *	FTRS2	Non-ACM										0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
009	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
	Z1	SCTM	STRUCTURAL CLAY TILE & MORTAR	SCT	Exempt										0 sf
	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt										0 sf
	ZR	DIR	DUCT INSULATION, Replacement NOTE: Fiberglass w / foil jacket.	DIR	Non-Suspect										0 sf
	Z1	DWJC	WALLBOARD, Drywall/Joint Compound System	DW	Non-ACM										0 sf
	ZR	DWJC	WALLBOARD, Drywall/Joint Compound System	DWJC	Non-Suspect										0 sf
	Z1	FDWM	FIRE DOORS, Wood Shell w / Mineral Core	FD2	Non-ACM										1 ea
	Z1	FTRSBN	FLOOR TILE REDUCING STRIPS, Brown Vinyl *	FTRS2	Non-ACM										0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	Z1	PIAC	PIPE INSULATION, Air Cell & Associated Fittings	PIAC	ACM	N	ND	N	N	N		LPD 14	O&M		7 lf
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
010	Z1	BFBM	BOILER FIRE BRICK & MORTAR	BI	Non-ACM										20 sf
	Z1	BLIF	BOILER LINING/INSULATION, [Interior] Fiberglass	BLIF	Non-Suspect										0 sf
	Z1	BM	BRICK & MORTAR	B	Exempt										0 sf
	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt										0 sf
	Z1	DWJC	WALLBOARD, Drywall/Joint Compound System	DW	Non-ACM										0 sf
	Z1	FDWM	FIRE DOORS, Wood Shell w / Mineral Core	FD2	Non-ACM										1 ea
	Z1	FP	FLUE PACKING NOTE: @ boiler breeching & vent pipes.	FG	ACM	N	ND	N	N	N		LPD 14	O&M		5 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	Z1	PIAC	PIPE INSULATION, Air Cell & Associated Fittings NOTE: Quantity includes an estimated 25 lf inside verticle chase feeding the ATTIC.	PIAC	ACM	N	ND	N	N	N		LPD 14	O&M		35 lf
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
	Z1	PIM	PIPE INSULATION, Magnesia & Associated Fittings	PIM	ACM	Y	ND	N	N	N		7 LPD 11	O&M		28 lf
	Z1	PP	PLASTER PATCH, Smooth/Sandfloat Finish	P3	Non-ACM										0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

REPORT OF BUILDING MATERIALS for						F r i a b l e	C o n d i t i o n	A c c e s s	D e b r i s	A i r f l o w	A H E R A #	P F D	P r i o r i t y	Sorted by: Area/Matl/Zone		
HEADSTART CENTER FOR CHILDREN														Disposition All	Selected:	
Materials printed in BOLD must be treated as Asbestos Containing Materials																
Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition									Response	Quantity	
013	Z1	SCTM	STRUCTURAL CLAY TILE & MORTAR	SCT	Exempt										0 sf	
	Z1	CT11M*	CEILING TILE, 12"x12" Mineral Board Panels *	CT6	Non-ACM										0 sf	
	Z1	CTM	CEILING TILE MASTIC	CT6M	Non-ACM										0 sf	
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf	
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect										0 sf	
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf	
	ZR	PIFZ	PIPE INSULATION, Fiberglass w/ Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf	
ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect										0 sf		
102	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt										0 sf	
	ZR	CPTMR	CARPETING, Replacement & Associated Mastic	CPTMR	Non-Suspect										0 sf	
	Z1	CT11M*	CEILING TILE, 12"x12" Mineral Board Panels * └ NOTE: Partially above ceiling.	CT6	Non-ACM										0 sf	
	Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT2	Non-ACM										0 sf	
	Z1	CTBDW	CEILING TILE BACKING BOARD, Dryw all Sheeting └ NOTE: Partially above ceiling.	RL	Non-ACM										0 sf	
	Z1	CTM	CEILING TILE MASTIC	CT6M	Non-ACM										0 sf	
	ZR	CTR	CEILING TILE, Replacement Panels └ NOTE: Patch tile.	CTR	Non-Suspect										0 sf	
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting	DI	Non-Suspect										0 sf	
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf	
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf	
	Z1	P	PLASTER, Smooth/Sandfloat Finish └ NOTE: Partially above ceiling.	P4	Non-ACM										0 sf	
	Z1	PD	PLASTER, Decorative Finish	P5	Non-ACM										0 sf	
	Z1	PIAC	PIPE INSULATION, Air Cell & Associated Fittings └ NOTE: Estimated quantity above plaster ceiling betw een joists (only 2 lf visible).	PIAC	ACM	N	ND	N	N	N	LPD 14	O&M	25 lf			
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf	
	Z1	PR	PLASTER, Rough Finish	P1	Non-ACM										0 sf	
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect										0 sf	
	103	Z1	C	CONCRETE, Floors/Walls/Ceilings └ NOTE: Beneath carpeting.	C	Exempt										0 sf
		Z1	CPMPF	CEILING PANELS, Metal Pan w/ Fiberglass Backing └ NOTE: Above ceiling.	CT3	Non-Suspect										0 sf
		ZR	CPTMR	CARPETING, Replacement & Associated Mastic └ NOTE: Over concrete.	CPTMR	Non-Suspect										0 sf
		Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT1	Non-ACM										0 sf
		Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT2	Non-ACM										0 sf
Z1		CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT4	Non-ACM										0 sf	
ZR		CTR	CEILING TILE, Replacement Panels	CTR	Non-Suspect										0 sf	
Z1		DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting └ NOTE: Above ceiling.	DI	Non-Suspect										0 sf	
Z1		DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf	

* Must check the Disposition of the mastic associated w ith this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

REPORT OF BUILDING MATERIALS for						F r i a b l e	C o n d i t i o n	A c c e s s	D e b r i s	A i r f l o w	A H E R A #	P F D	P r i o r i t y	Sorted by: Area/Matl/Zone Disposition All Selected:	
Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition									Response	Quantity
104	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf
	Z1	PD	PLASTER, Decorative Finish └─ NOTE: Above ceiling.	P5	Non-ACM										0 sf
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
	Z1	PR	PLASTER, Rough Finish └─ NOTE: Above ceiling.	P1	Non-ACM										0 sf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect										0 sf
	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt										0 sf
	Z1	CPMPF	CEILING PANELS, Metal Pan w / Fiberglass Backing └─ NOTE: Above new ceiling tile.	CT3	Non-Suspect										0 sf
	Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT1	Non-ACM										0 sf
	Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT2	Non-ACM										0 sf
	Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT4	Non-ACM										0 sf
	ZR	CTR	CEILING TILE, Replacement Panels	CTR	Non-Suspect										0 sf
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting	DI	Non-Suspect										0 sf
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect										0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt										0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	Z1	PD	PLASTER, Decorative Finish └─ NOTE: Partially above ceiling.	P5	Non-ACM										0 sf
	Z1	PIAC	PIPE INSULATION, Air Cell & Associated Fittings └─ NOTE: Estimated quantity above plaster ceiling betw een joists (only 4 lf visible).	PIAC	ACM	N	ND	N	N	N		LPD 14	O&M		30 lf
	Z1	PICF	PIPE INSULATION, Cellular Foam	PICF	Non-Suspect										0 lf
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
	Z1	PIWF	PIPE INSULATION, Woolfelt & Associated Fittings └─ NOTE: Estimated quantity above plaster ceiling betw een joists.	PIW	ACM	N	ND	N	N	N		LPD 14	O&M		25 lf
	Z1	PP	PLASTER PATCH, Smooth/Sandfloat Finish └─ NOTE: Above ceiling.	P3	Non-ACM										0 sf
	Z1	PR	PLASTER, Rough Finish └─ NOTE: Partially above ceiling.	P1	Non-ACM										0 sf
Z1	WCV	WALL COVERING, Vinyl └─ NOTE: Coloration: yellow .	VWC	Non-Suspect										0 sf	
105B	ZR	CTGR	CERAMIC WALL TILE, Replacement Tile, Grout & Associated Mastic	CTGR	Non-Suspect									0 sf	
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect									0 sf	
106B	ZR	CTGR	CERAMIC WALL TILE, Replacement Tile, Grout & Associated Mastic	CTGR	Non-Suspect									0 sf	
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect									0 sf	
	ZR	MFT	MOSAIC FLOOR TILE & MORTAR	MTM	Exempt									0 sf	

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

REPORT OF BUILDING MATERIALS for						F r i a b l e	C o n d i t i o n	A c c e s s	D e b r i s	A i r f l o w	A H E R A #	P F D	P r i o r i t y	Sorted by: Area/Matl/Zone				
														Disposition All				
														Selected:				
HEADSTART CENTER FOR CHILDREN																		
Materials printed in BOLD must be treated as Asbestos Containing Materials																		
Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition												Response	Quantity
107B	ZR	CTGR	CERAMIC WALL TILE, Replacement Tile, Grout & Associated Mastic	CTGR	Non-Suspect													0 sf
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect													0 sf
	ZR	MFT	MOSAIC FLOOR TILE & MORTAR	MTM	Exempt													0 sf
201	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM													0 sf
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12		O&M	100 sf				
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14		O&M	100 sf				
	ZR	FTRP	FLOOR TILE, Replacement Patches	FTR	Non-Suspect													0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM													0 sf
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *	WB1	Non-ACM													0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM													0 sf
202	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM													0 sf
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12		O&M	120 sf				
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14		O&M	120 sf				
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM													0 sf
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *	WB1	Non-ACM													0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM													0 sf
203	ZR	CPTMR	CARPETING, Replacement & Associated Mastic	CPTMR	Non-Suspect													0 sf
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM													0 sf
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect													0 sf
	Z1	FLC	FLOOR LEVELING COMPOUND	FLC	Non-ACM													0 sf
	Z1	FSCK	SHEET FLOORING, Cork *	FT5	Non-Suspect													0 sf
			NOTE: Thin cork flooring beneath carpeting.															
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12		O&M	400 sf				
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14		O&M	400 sf				
	ZR	FTRP	FLOOR TILE, Replacement Patches	FTR	Non-Suspect													0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM													0 sf
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect													0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect													0 lf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect													0 sf
203A	ZR	CPTMR	CARPETING, Replacement & Associated Mastic	CPTMR	Non-Suspect													0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM													0 sf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect													0 sf
205	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM													0 sf
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	D	Y	N	N	SPD 6		Repair	25 sf				
			NOTE: Missing tile.															
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	Y	N	N	SPD 12		O&M	25 sf				
	ZR	FTRP	FLOOR TILE, Replacement Patches	FTR	Non-Suspect													0 sf
	Z1	WB6B	WALL BASE, 6" Brow n Vinyl *	WB2	Non-ACM													0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM													0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

REPORT OF BUILDING MATERIALS for						F	r	i	a	b	l	e	C	o	n	d	i	t	i	o	n	A	c	c	e	s	D	e	b	r	i	s	A	i	r	f	l	o	w	#	A	H	E	R	A	P	F	D	P	r	i	o	r	i	t	y	Sorted by: Area/Mat/Zone	
Disposition All		Selected:																																																								
HEADSTART CENTER FOR CHILDREN																																																										
Materials printed in BOLD must be treated as Asbestos Containing Materials																																																										
Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition																															Response	Quantity																					
206B	ZR	CTGR	CERAMIC WALL TILE, Replacement Tile, Grout & Associated Mastic	CTGR	Non-Suspect																																0 sf																					
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect																																0 sf																					
	ZR	MFT	MOSAIC FLOOR TILE & MORTAR	MTM	Exempt																																0 sf																					
207B	ZR	CTGR	CERAMIC WALL TILE, Replacement Tile, Grout & Associated Mastic	CTGR	Non-Suspect																																0 sf																					
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect																																0 sf																					
	ZR	MFT	MOSAIC FLOOR TILE & MORTAR	MTM	Exempt																																0 sf																					
208	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM																																0 sf																					
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect																																0 sf																					
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12	O&M	440 sf																																													
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14	O&M	440 sf																																													
	ZR	FTRP	FLOOR TILE, Replacement Patches	FTR	Non-Suspect																																0 sf																					
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM																																0 sf																					
	Z1	PICF	PIPE INSULATION, Cellular Foam	PICF	Non-Suspect																																0 lf																					
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect																																0 lf																					
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect																																0 sf																					
			NOTE: Gray.																																																							
ATTIC	Z1	BM	BRICK & MORTAR	B	Exempt																																0 sf																					
	ZR	DIR	DUCT INSULATION, Replacement	DIR	Non-Suspect																																0 sf																					
			NOTE: Fiberglass w / foil jacket.																																																							
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect																																0 sf																					
	Z1	INSLRW	INSULATION, Loose Rockwool	INS	Non-ACM																																0 sf																					
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect																																0 lf																					
	Z1	PIM	PIPE INSULATION, Magnesia & Associated Fittings	PIM	ACM	N	ND	N	Y	N	PD 13	O&M	175 lf																																													
	Z1	SCTM	STRUCTURAL CLAY TILE & MORTAR	SCT	Exempt																																0 sf																					
CORR 1-1	Z1	CPMPF	CEILING PANELS, Metal Pan w / Fiberglass Backing	CT3	Non-Suspect																																0 sf																					
			NOTE: Above new suspended ceiling tile.																																																							
	Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT1	Non-ACM																																0 sf																					
	Z1	CTBDW	CEILING TILE BACKING BOARD, Dryw all Sheeting	RL	Non-ACM																																0 sf																					
			NOTE: Above ceiling.																																																							
	ZR	CTR	CEILING TILE, Replacement Panels	CTR	Non-Suspect																																0 sf																					
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM																																0 sf																					
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect																																0 sf																					
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect																																0 sf																					
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt																																0 sf																					
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM																																0 sf																					
			NOTE: Above ceiling.																																																							
	Z1	PD	PLASTER, Decorative Finish	P5	Non-ACM																																0 sf																					
			NOTE: Above ceiling.																																																							
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect																																0 lf																					
	Z1	PR	PLASTER, Rough Finish	P1	Non-ACM																																0 sf																					
		NOTE: Above ceiling.																																																								

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

REPORT OF BUILDING MATERIALS for						F r i a b l e	C o n d i t i o n	A c c e s s	D e b r i s	A i r f l o w	A H E R A #	P F D	P r i o r i t y	Sorted by: Area/Matl/Zone Disposition All Selected:	
Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition									Response	Quantity
CORR 2-1	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic └ NOTE: Gray.	WBR4	Non-Suspect										0 sf
	Z1	WCV	WALL COVERING, Vinyl └ NOTE: Coloration: yellow.	VWC	Non-Suspect										0 sf
	ZR	CTGR	CERAMIC WALL TILE, Replacement Tile, Grout & Associated Mastic	CTGR	Non-Suspect										0 sf
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12	O&M		300 sf	
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14	O&M		300 sf	
	ZR	FTRP	FLOOR TILE, Replacement Patches	FTR	Non-Suspect										0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
CORR B-1	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic └ NOTE: Gray.	WBR4	Non-Suspect										0 sf
	Z1	CT24M	CEILING TILE, 2'x4' Mineral Board Panels	CT2	Non-ACM										0 sf
	ZR	CTR	CEILING TILE, Replacement Panels └ NOTE: Patch tile.	CTR	Non-Suspect										0 sf
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl * └ NOTE: Loose tile.	FT1	ACM	N	D	Y	N	N	SPD 6	Repair		75 sf	
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14	O&M		100 sf	
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	Z1	PIAC	PIPE INSULATION, Air Cell & Associated Fittings └ NOTE: Above ceiling.	PIAC	ACM	N	ND	N	N	N	LPD 14	O&M		6 lf	
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings └ NOTE: Above ceiling.	PIFZ	Non-Suspect										0 lf
CORR B-1A	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
	Z1	BM	BRICK & MORTAR	B	Exempt										0 sf
	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt										0 sf
	Z1	CT24G	CEILING TILE, 2'x4' Gypsum Board Panels	CT5	Non-ACM										0 sf
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf
	ZR	FDR	FIRE DOORS, Replacement	FDR	Non-Suspect										0 ea
	Z1	FDWM	FIRE DOORS, Wood Shell w / Mineral Core	FD2	Non-ACM										1 ea
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12	O&M		75 sf	
Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14	O&M		75 sf		
Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf	
Z1	SCTM	STRUCTURAL CLAY TILE & MORTAR	SCT	Exempt										0 sf	
Z1	STVB	STAIR TREADS, Brown Vinyl *	ST2	Non-ACM										0 sf	
Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf	

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

REPORT OF BUILDING MATERIALS for						F r i a b l e	C o n d i t i o n	A c c e s s	D e b r i s	A i r f l o w	A H E R A #	P F D	P r i o r i t y	Sorted by: Area/Matl/Zone Disposition All Selected:	
Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition									Response	Quantity
ELEV 1	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect										0 sf
EXIT 1	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12	O&M		50 sf	
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14	O&M		50 sf	
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
EXIT 3	ZR	CTR	CEILING TILE, Replacement Panels	CTR	Non-Suspect										0 sf
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect										0 sf
	ZR	FTRSR	FLOOR TILE REDUCING STRIPS, Replacement Vinyl	FTRRS	Non-Suspect										0 sf
	Z1	P	PLASTER, Smooth/Sandfloat Finish	P4	Non-ACM										0 sf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings └ NOTE: Above ceiling.	PIFZ	Non-Suspect										0 lf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect										0 sf
EXTERIOR	Z1	WDC	WINDOW/DOOR CAULKING └ NOTE: Residual caulking by EXIT 1 & EXIT 2.	WDC	Non-ACM										2 sf
	ZR	WDCR	WINDOW/DOOR CAULKING, Replacement └ NOTE: Residual ACM caulking may remain beneath new window frames.	WDCR	Non-Suspect										0 sf
	ZR	WGCR	WINDOW GLAZING COMPOUND, Replacement	WGCR	Non-Suspect										0 sf
STAIR 1	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System	DW	Non-ACM										0 sf
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect										0 sf
	ZR	FDR	FIRE DOORS, Replacement	FDR	Non-Suspect										2 ea
	Z1	FSM	SHEET FLOORING MASTIC	FSM	Non-ACM										0 sf
	Z1	FSVRD	SHEET FLOORING, Red Vinyl * └ NOTE: White accenting.	FS1	Non-ACM										0 sf
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12	O&M		100 sf	
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14	O&M		100 sf	
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect										0 sf
	Z1	FTRSBK	FLOOR TILE REDUCING STRIPS, Black Vinyl *	FTRSR	Non-ACM										0 sf
	ZR	FTRSR	FLOOR TILE REDUCING STRIPS, Replacement Vinyl	FTRRS	Non-Suspect										0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt										0 sf
	Z1	PICF	PIPE INSULATION, Cellular Foam	PICF	Non-Suspect										0 lf
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
	Z1	PS	PLASTER, Stucco Finish	P6	Non-ACM**										0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for HEADSTART CENTER FOR CHILDREN

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

MPS Site #: 486 Date: 01/16/2015						REPORT OF BUILDING MATERIALS for								F r i a b l e		C o n d i t i o n		A c c e s s		D e b r i s		A i r f l o w		A H E R A #		P F D		P r i o r i t y		Sorted by: Area/Matl/Zone Disposition All Selected:			
HEADSTART CENTER FOR CHILDREN																																	
Materials printed in BOLD must be treated as Asbestos Containing Materials																																	
Area ID	Zone	Matl Code	Material Description (notes if applicable)			S. Link	Disposition												Response		Quantity												
	Z1	QFTM	QUARRY FLOOR TILE & MORTAR			QT	Exempt														0 sf												
	Z1	STM	STAIR TREAD MASTIC			STM	ACM		N	ND	N	N	N	LPD 14		O&M	100 sf																
	Z1	STVT	STAIR TREADS, Tan Vinyl *			ST1	Non-ACM														0 sf												
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *			WB1	Non-ACM														0 sf												
	Z1	WB6B	WALL BASE, 6" Brow n Vinyl *			WB2	Non-ACM														0 sf												
	Z1	WBM	WALL BASE MASTIC			WBM	Non-ACM														0 sf												
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic			WBR4	Non-Suspect														0 sf												
STAIR 2	ZR	FTRSR	FLOOR TILE REDUCING STRIPS, Replacement Vinyl			FTRRS	Non-Suspect														0 sf												
	Z1	P	PLASTER, Smooth/Sandfloat Finish			P4	Non-ACM														0 sf												
	Z1	STM	STAIR TREAD MASTIC			STM	ACM		N	ND	N	N	N	LPD 14		O&M	64 sf																
	Z1	STVB	STAIR TREADS, Brow n Vinyl *			ST2	Non-ACM														0 sf												
	Z1	WB6B	WALL BASE, 6" Brow n Vinyl *			WB2	Non-ACM														0 sf												
	Z1	WBM	WALL BASE MASTIC			WBM	Non-ACM														0 sf												
STAIR 2A	ZR	CTR	CEILING TILE, Replacement Panels			CTR	Non-Suspect														0 sf												
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System			DW	Non-ACM														0 sf												
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System			DWJC	Non-Suspect														0 sf												
	ZR	FDR	FIRE DOORS, Replacement			FDR	Non-Suspect														0 ea												
	Z1	FSVBN	SHEET FLOORING, Brow n Vinyl *			FS4	Non-ACM														0 sf												
			└─ NOTE: Orange accenting. Beneath vinyl stair treads.																														
	Z1	FT12LTN	FLOOR TILE, 12"x12" Light Tan Vinyl *			FT1	ACM		N	ND	Y	N	N	SPD 12		O&M	125 sf																
	Z1	FTM	FLOOR TILE MASTIC			FTM	ACM		N	ND	N	N	N	LPD 14		O&M	125 sf																
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic			FTR	Non-Suspect														0 sf												
	Z1	P	PLASTER, Smooth/Sandfloat Finish			P4	Non-ACM														0 sf												
	Z1	PICF	PIPE INSULATION, Cellular Foam			PICF	Non-Suspect														0 lf												
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings			PIFZ	Non-Suspect														0 lf												
			└─ NOTE: Above ceiling.																														
	Z1	STM	STAIR TREAD MASTIC			STM	ACM		N	ND	N	N	N	LPD 14		O&M	140 sf																
	Z1	STVB	STAIR TREADS, Brow n Vinyl *			ST2	Non-ACM														0 sf												
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *			WB1	Non-ACM														0 sf												
	Z1	WB6B	WALL BASE, 6" Brow n Vinyl *			WB2	Non-ACM														0 sf												
	Z1	WBM	WALL BASE MASTIC			WBM	Non-ACM														0 sf												
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic			WBR4	Non-Suspect														0 sf												

Total Record Count: 344 Total Area Count: 37

Matl Types Selected: ALL

Areas Selected: ALL

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)